

Government of Rajasthan

Department of Archaeology and Museum, Ramniwas Garden, Albert Hall, Jaipur.

Tel.0141-5190400, Fax No. 0141-565124 & email-dirarch\_raj@rediffmail.com

No. A&M/EE/2017/ 8761


Dated : 31/8/17

:: CORRIGENDUM ::

Online E-bid. No. 1/2017-18 for "Facade Illumination of Major Arterial Roads of Walled City, Jaipur" was invited vide letter No. NIT-1/2017-18/7001-7011 dated 19.6.17. In response to pre-bid conference held on dated 31.7.17, corrigendum as follows is issued to clarify the doubts of potential bidders:-

1. Equivalent means "Equivalent Brand of International standing with a product of similar specifications and quality (with the desired color temperature and beam angle). The product should be available in the vendor catalogue or website since 1<sup>st</sup> May, 2017".
2. For item numbers : 12,13,21,22,28,29,30,31,32,33,34 and 35 – the color temperature may be read as 2700 degree Kelvin with the tolerance of  $\pm 100$  instead of  $\pm 300$ .
3. For item numbers: 17,18,19,20 the color temperature may be read as 2400 degree Kelvin with the tolerance of  $\pm 100$  instead of  $\pm 300$ .
4. For item numbers : 12,13,14,15,16,28,47,48,43 and 44 – 'Phillips' may be read as 'Phillips Color Kinetics'.
5. The desired pink color shall be achieved by mixing (a) 4000 degree Kelvin LEDs (b) Red LEDs and (c) Blue LEDs in the ratio 10:7:3 (All LEDs have been taken as 1 watt each, saturated Red and Blue LEDs have been taken)
6. Detailed drawings of the stone decorative fixtures (namely the wall light, the Bollord and post Top) has been updated as addendum and the same has been uploaded on <http://sppp.rajasthan.gov.in> and <http://eproc.rajasthan.gov.in>.
7. Up to 15 mock Ups, for both the lighting effect and installation details shall be required. Further, all the samples shall be required to be approved by the consultant and the department.
8. Bank Guarantee in lieu of work performance security is acceptable if successful bidder submits B.G. of equivalent amount at the time of signing of the contract agreement.
9. Part-B - BOQ item no. 10.1 & 2 the words G.I. conduits shall be read as G.I. pipes and in item no. 11 junction box (IP65) shall be read as IP 65 thermoplastic readymade panels.
10. Bid downloading and uploading dates shall be read as 16.08.17 and 17.08.17 respectively in place of 09.08.17 and 10.08.17.

Rest terms and conditions shall remain unchanged.

  
Executive Engineer